

Certificate



SIL/PL
Capability

www.tuv.com
ID 060000000

Nr./No.: 968/V 1203.00/20

Prüfgegenstand Product tested	Zentrische Drossel- und Abdichtklappen Control and on/off butterfly valves	Zertifikats- inhaber Certificate holder	Herberholz GmbH Pregelstr. 6 58256 Ennepetal Germany
Typbezeichnung Type designation	HRD Series (015 / 018 and 016 / 019), HRA Series (015 / 018 and 016 / 019)		
Prüfgrundlagen Codes and standards	IEC 61508 Parts 1-2 and 4-7:2010		
Bestimmungsgemäße Verwendung Intended application	Sicherheitsfunktion: Sicheres Schließen oder Öffnen der Klappe bei Anforderung. Die Armaturen sind zur Verwendung in einem sicherheitsgerichteten System bis SIL 2 geeignet (low demand mode). Unter Berücksichtigung der mindestens erforderlichen Hardware-Fehlertoleranz von HFT=1 können die Armaturen in redundanter Ausführung auch bis SIL 3 eingesetzt werden. Safety function: Move into closed position or into open position upon demand. The valves are suitable for use in a safety instrumented system up to SIL 2 (low demand mode). Under consideration of the minimum required hardware fault tolerance HFT=1 the valves may be used in a redundant structure up to SIL 3.		
Besondere Bedingungen Specific requirements	Die Hinweise in der zugehörigen Installations- und Betriebsanleitung sowie des Sicherheitshandbuchs sind zu beachten. The instructions of the associated Installation, Operating and Safety Manual shall be considered.		

Zusammenfassung der Testergebnisse siehe Rückseite des Zertifikates.
Summary of test results see back side of this certificate.

Gültig bis / Valid until 2025-12-16


Der Ausstellung dieses Zertifikates liegt eine Evaluierung entsprechend dem Zertifizierungsprogramm
CERT FSP1 V1.0:2017 in der aktuellen Version zugrunde, deren Ergebnisse im Bericht Nr. 968/V 1203.00/20 vom
07.12.2020 dokumentiert sind. Dieses Zertifikat ist nur gültig für Erzeugnisse, die mit dem Prüfgegenstand
übereinstimmen.

The issue of this certificate is based upon an evaluation in accordance with the Certification Program
CERT FSP1 V1.0:2017 in its actual version, whose results are documented in Report No. 968/V 1203.00/20 dated
2020-12-07. This certificate is valid only for products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit

Köln, 2020-12-16

Certification Body Safety & Security for Automation & Grid


Dipl.-Ing. (FH) Wolf Rückwart

Holder: Herberholz GmbH
Pregelstraße 6
D-58256 Ennepetal
Germany

Product tested: Control and on/off butterfly valves
HRD / HRA
Series: 016 / 019, 015 / 018

Results of Assessment

Route of Assessment		$2_H / 1_S$
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		SC 3

Closing on Demand

Dangerous Failure Rate	λ_D	4.60 E-07 / h	460 FIT
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	2.05 E-03	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	2.09 E-04	

Open on Demand

Dangerous Failure Rate	λ_D	3.85 E-07 / h	385 FIT
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	1.71 E-03	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	1.75 E-04	

Assumptions for the calculations above: DC = 0 %, $T_1 = 1$ year, MRT = 72 h, $\beta_{1oo2} = 10$ %

Origin of failure rates

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process.

Furthermore the results have been verified by field-feedback data.

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing.

The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.